

Komponent	Resultat	Enhed	DL	Metode	Um (%)
Coliforme bakterier 37°C	< 1	MPN/100 ml	1	ISO 9308-2:2012	0.25σ
Escherichia coli	< 1	MPN/100 ml	1	ISO 9308-2:2012	0.25σ
Intestinale Enterokokker	< 1	CFU/100 ml	1	ISO 7899-2:2000	0.11σ
Kimtal ved 22°C	< 1	CFU/ml	1	ISO 6222:1999	0.15σ
Ammonium (NH ₄)	< 0,005	mg/l	0,005	SM 17. udg. 4500-NH ₃ (H)	15
Chlorid	54	mg/l	1	DS ISO 15923-1:2013	15
Cyanid, total	< 1	µg/l	1	DS/EN ISO 14403:2012	15
Fluorid	0,84	mg/l	0,05	DS/ISO/TS 15923-2:2017	15
Nitrat	1,3	mg/l	0,3	DS/ISO 15923-1:2013, mod	15
Nitrit	0,0095	mg/l	0,001	DS ISO 15923-1:2013	15
Sulfat (SO ₄)	63	mg/l	0,5	DS ISO 15923-1:2013	15
Hårdhed, total	23	°dH	0,1	DS/EN ISO 17294m:2023 ICP-MS	20
Calcium (Ca)	120	mg/l	0,5	DS/EN ISO 17294m:2023 ICP-MS	20
Magnesium (Mg)	28	mg/l	0,1	DS/EN ISO 17294m:2023 ICP-MS	20
NVOC, ikke-flygtigt org. kulstof	1,2	mg/l	0,1	DS/EN 1484:1997	15
Aluminium (Al)	1,1	µg/l	0,2	DS/EN ISO 17294m:2023 ICP-MS	20
Antimon (Sb)	< 0,2	µg/l	0,2	DS/EN ISO 17294m:2023 ICP-MS	20
Arsen (As)	0,88	µg/l	0,03	DS/EN ISO 17294m:2023 ICP-MS	20
Bly (Pb)	0,54	µg/l	0,025	DS/EN ISO 17294m:2023 ICP-MS	20
Bor (B)	170	µg/l	1	DS/EN ISO 17294m:2023 ICP-MS	20
Cadmium (Cd)	0,0061	µg/l	0,003	DS/EN ISO 17294m:2023 ICP-MS	20
Chrom (Cr)	< 0,03	µg/l	0,03	DS/EN ISO 17294m:2023 ICP-MS	20
Jern (Fe)	0,013	mg/l	0,01	DS/EN ISO 17294m:2023 ICP-MS	20
Kobber (Cu)	3,4	µg/l	0,03	DS/EN ISO 17294m:2023 ICP-MS	20
Kobolt (Co)	0,28	µg/l	0,04	DS/EN ISO 17294m:2023 ICP-MS	20
Kviksølv (Hg)	< 0,001	µg/l	0,001	EPA 245.7 CV-AFS	20
Mangan (Mn)	0,008	mg/l	0,002	DS/EN ISO 17294m:2023 ICP-MS	20
Natrium (Na)	33	mg/l	0,1	DS/EN ISO 17294m:2023 ICP-MS	15
Nikkel (Ni)	5,1	µg/l	0,03	DS/EN ISO 17294m:2023 ICP-MS	20
Selen (Se)	< 0,05	µg/l	0,05	DS/EN ISO 17294m:2023 ICP-MS	20
Zink (Zn)	30	µg/l	0,3	DS/EN ISO 17294m:2023 ICP-MS	20
Acrylamid	< 0,05	µg/l	0,05	M 0336 LC-MS/MS	30
Epichlorhydrin	< 0,05	µg/l	0,05	ISO 15680: 2004 P&T-GC-MS	30
Fluoranthen	< 0,005	µg/l	0,005	M 0250 GC-MS	30
Benzo(b)fluoranthen	< 0,005	µg/l	0,005	M 0250 GC-MS	30
Benzo(k)fluoranthen	< 0,005	µg/l	0,005	M 0250 GC-MS	30
Benzo(a)pyren	< 0,003	µg/l	0,003	M 0250 GC-MS	30
Indeno(1,2,3-cd)pyren	< 0,005	µg/l	0,005	M 0250 GC-MS	30
Benzo(g,h,i)perylene	< 0,005	µg/l	0,005	M 0250 GC-MS	30
PFBA (Perfluorbutansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFBS (Perfluorbutansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFPeA (Perfluorpentansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFPeS (Perfluorpentansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFHxA (Perfluorhexansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFHxS, lineær	0,0002	µg/l	0,00005	M 0441 LC-MS/MS	50
PFHxS, lineær og forgrenet	0,0003	µg/l	0,00005	M 0441 LC-MS/MS	50
PFHpA (Perfluorheptansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFHpS (Perfluorheptansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFOA, lineær	< 0,00005	µg/l	0,00005	M 0441 LC-MS/MS	50
PFOA, lineær og forgrenet	< 0,00005	µg/l	0,00005	M 0441 LC-MS/MS	50
PFOS, lineær	< 0,00005	µg/l	0,00005	M 0441 LC-MS/MS	50
PFOS, lineær og forgrenet	< 0,00005	µg/l	0,00005	M 0441 LC-MS/MS	50
6:2 FTS (Fluortelomersulfonat)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFOSA, lineær	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFOSA, lineær og forgrenet	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFNA, lineær	< 0,00005	µg/l	0,00005	M 0441 LC-MS/MS	50
PFNA, lineær og forgrenet	< 0,00005	µg/l	0,00005	M 0441 LC-MS/MS	50
PFNS (Perfluoronansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFDA (Perfluordekansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFDS (Perfluordekansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFUnDA (Perfluorundekansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFUnDS (Perfluorundekansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFDODA (Perfluordodekansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFDODS (Perfluordodekansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
PFTrDA (Perfluortridekansyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50

PFTrDS (Perfluortridekansulfonsyre)	< 0,001	µg/l	0,001	M 0441 LC-MS/MS	50
Sum af 4 PFAS (lineær)	0,0002	µg/l			
Sum af 4 PFAS (lineær+forgrenet)	0,0003	µg/l			
Sum af 22 PFAS (lineær)	0,0002	µg/l			
Sum af 22 PFAS (PFOS, PFOA, PFHxS, PFNA, PF	0,0003	µg/l			
Pentachlorphenol	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
2,4-dichlorphenol	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
2,6-DCPP (2-(2,6-dichlorphenoxy-propionsyre))	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
2,6-dichlorbenzosyre	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
[(2,6-Dimethylphenyl)(2-sulfoacetyl)amino]eddikesy	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
4-Bis-amido-3,5,6-trichlorbenzensulfonat (R47181)	0,016	µg/l	0,01	M 0424 LC-MS/MS	30
4-CPP	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
4-(tert-Butylamino)-6-hydroxy-1-methyl-1,3,5-triaz	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
6-(tert-Butylamino)-1,3,5-triazine-2,4-diol (LM5)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Acetochlor SAA (t-sulfinyl eddikesyre)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Alachlor ESA	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Aldrin	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
AMPA (Aminomethylphosphorsyre)	< 0,01	µg/l	0,01	M 8270 LC-MS/MS	30
Atrazin	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Atrazin, deisopropyl-2-hydroxy-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Atrazin, desethyl-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Atrazin, desethyl-desisopropyl-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Atrazin, desisopropyl-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Atrazin, didealkyl-hydroxy-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
BAM (2,6-dichlorbenzamid)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Bentazon	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Chloridazon, desphenyl-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Chloridazon, methyl-desphenyl-	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Chlorothalonil-amidsulfonsyre (CTA)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Dichlorprop (2,4-DP)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Dieldrin	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
(2,6-Dimethyl-phenylcarbamoyl)-methansulfonsyre	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Dimethachlor ESA (CGA 354742)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Dimethachlor OA (CGA 50266)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Ethylenthiourea (ETU)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Glyphosat	< 0,01	µg/l	0,01	M 8270 LC-MS/MS	30
Heptachlor	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
Heptachlorepoxyd (sum af cis+trans)	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
Hexazinon	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Imazail (any ratio of constituent isomers)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
PPU(IN70941)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
LM3,metabolit af terbuthylazin SYN 546009	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Mechlorprop (MCPP)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Metaldehyd	< 0,01	µg/l	0,01	M 0424 LC-MS/MS	30
Metamitron-desamino	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Metazachlor ESA	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Metazachlor OA (479-4)	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Monuron	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
N,N-dimethylsulfamid, DMS	0,025	µg/l	0,01	M 0336 LC-MS/MS	30
Pentachlorbenzen	< 0,01	µg/l	0,01	M 0352 GC-MS/MS	30
Propachlor ESA	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Simazin	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
TFMP	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
4-nitrophenol	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Vinylchlorid	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	30
Dichlormethan	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,1-dichlorethen	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,2-dichlorethan	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
cis-1,2-dichlorethen	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
trans-1,2-dichlorethen	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,1,1-trichlorethan	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,1,2-trichlorethan	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
Trichlorethen	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,1,1,2-tetrachlorethan	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,1,2,2-tetrachlorethan	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
Tetrachlorethen	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
Trichlormethan (Chloroform)	< 0,02	µg/l	0,02	ISO 15680: 2004 P&T-GC-MS	20
1,2,4-triazol	< 0,01	µg/l	0,01	M 0336 LC-MS/MS	30
Trifluoreddikesyre, TFA	0,087	µg/l	0,05	M 0411 LC-MS/MS	30
Akkrediteret prøvetagning	Ja			DS ISO 5667-5:2006, MST - Drikkevand. Manual for prøvetagning (v5,2021 N/A	
pH	7,4	pH		DS/EN ISO 10523:2012	
Prøvetagning efter flush	Udført			DS ISO 5667-5:2006,DS/EN ISO 19458:2006, MST - Drikkevand. Manual for prøvetagning (v5,2021 N/A	
Vandtemperatur	8,7	°C		DS/EN ISO 19458:2006	
Ledningsevne ved 20°C	740	µS/cm	15	DS/EN 27888:2003 (ved 20°C)	
littindhold	9,9	mg/l	0,1	DS/EN ISO 5814:2012	15